



ECOFLOOR

Tabulka č. 144B

Revize	Číslo	Datum
	0	12/4/2017

Okruhy IN-THERM ECO PDSV xxxxx

Délkový odpor (Ohm/m)	Délka kabelu (m)	Odpor (Ohm)	Odpor +10%	Příkon (W)	Příkon +5%	SK ADSL1P	Šíře náviny (mm)																
			Odpor -5%		Příkon -10%																		
38,72	8	311,2	342,3	170	178,5	0,75	50																
			295,6		153																		
14,02	14	195,9	215,5	270	283,5			1,5	90														
			186,1		243																		
8,96	17	151,1	166,3	350	367,5					1,5	90												
			143,6		315																		
5,23	22	115,0	126,5	460	483							1,5	90										
			109,3		414																		
3,58	27	96,2	105,8	550	577,5									1,5	90								
			91,4		495																		
2,57	32	82,7	90,9	640	672	1,5										90							
			78,5		576																		
2,05	36	73,5	80,8	720	756												1,5	90					
			69,8		648																		
1,38	44	60,8	66,9	870	913,5														1,5	90			
			57,8		783																		
0,93	53	49,0	53,9	1080	1134																1,5	90	
			46,5		972																		
0,64	64	40,7	44,8	1300	1365		1,5																90
			38,7		1170																		
0,42	79	33,5	36,8	1580	1659			1,5	90														
			31,8		1422																		
0,31	92	28,6	31,5	1850	1942,5					1,5	90												
			27,2		1665																		
0,196	116	22,7	25,0	2330	2446,5							1,5	90										
			21,6		2097																		
0,136	139	19,0	20,9	2790	2929,5									1,5	90								
			18,0		2511																		

Červený kabel PDSV s potiskem:

HEATING CABLE * PDSV * xxx Ohm / m * 300/500V * M2 * IEC 60800 * CE * week/year

Studený konec SK ADSL1P délky 1,5 m

Zatavit do fólie

.